

Interoffice Memorandum  
September 9, 2002

To: Donald Van Buren  
From: Jane Lundquist *JHL*

*BB*  
Via: Brian Bateman

Subject: Revised Risk Screen for Xoma, Plant # 14263, A# 5034,  
Standby Emergency Generator Diesel Engine

At your request, a revised risk screening analysis was performed for the operation of a standby emergency generator diesel engine at two exhaust heights. Except for the stack height, the assumptions used in the model are the same as those used for the 31-foot exhaust height scenario in my memo to you dated September 4, 2002. For an exhaust height that is 20 feet above ground level, 9 hours of operation per year, excluding periods when operation is required due to emergency conditions, results in a maximum cancer risk of less than one in a million. For an exhaust height that is 26.5 feet above ground level, 29 hours of operation per year results in a maximum cancer risk of less than one in a million. The results are summarized in the tables below.

Vertical Exhaust at 20 Feet Above Ground Level								
Receptor	Hours of Operation per year	Engine Size, kW	DieselPM Emission Factor g/kW hr	Annual Average Emiss. Rate (g/s)	X/Q ( $\mu\text{g}/\text{m}^3$ ) / (g/s)	exposure adjustment factor	unit risk ( $\mu\text{g}/\text{m}^3$ ) <sup>-1</sup>	Cancer risk in a million
Non-residential	9	123	0.276	9.7 E-6	504	0.66	3.0 E-04	1
Residential	9	123	0.276	9.7 E-6	39.5	1	3.0 E-04	0.1
Emery Middle School	9	123	0.276	9.7 E-6	9.87	1	3.0 E-04	0.03

Vertical Exhaust at 26.5 Feet Above Ground Level								
Receptor	Hours of Operation per year	Engine Size, kW	DieselPM Emission Factor, g/kW hr	Annual Average Emiss. Rate (g/s)	X/Q ( $\mu\text{g}/\text{m}^3$ ) / (g/s)	exposure adjustment factor	unit risk ( $\mu\text{g}/\text{m}^3$ ) <sup>-1</sup>	Cancer risk in a million
Non-residential	29	123	0.276	3.1 E-5	158	0.66	3.0 E-04	1
Residential	29	123	0.276	3.1 E-5	36.7	1	3.0 E-04	0.3
Emery Middle School	29	123	0.276	3.1 E-5	9.2	1	3.0 E-04	0.09